


GENERAL NOTES

- COORDINATE EXACT LOCATION OF EACH LIGHTING FIXTURE WITH CABLE TRAY LAYOUTS AND AIR DUCT LAYOUTS.
- FIXTURES SHALL BE LOCATED AT THE SAME ELEVATION IN EACH ROOM, UON.
- FOR LIGHTING PANEL SCHEDULES SEE DWG E9.21.34
- FOR LIGHTING FIXTURE SCHEDULES SEE DWG E9.30.01
- PROVIDE 2" RIGID GALVANIZED STEEL SLEEVES FOR ALL CONCRETE CEILING AND WALL CONDUIT PENETRATIONS. LOCATE WALL PENETRATIONS IN THE BASEMENT 12" BELOW CEILING. SEE DETAILS AS NOTED.
- ALL CONDUITS RUN IN THE CEILING AREA IN THE BASEMENT SHALL BE MINIMUM OF 8'-0" ABOVE THE FINISHED FLOOR.

SHEET KEYNOTES

N001 ALL CONDUITS, CONDUIT FITTINGS AND J-BOXES IN THIS ROOM SHALL BE NON CORROSIVE EPOXY COATED GALVANIZED RIGID STEEL. WIRING DEVICES (SWITCHES, ETC.) SHALL BE ENCLOSED IN EPOXY COATED STEEL OR STAINLESS STEEL ENCLOSURES.

N002 SEE DWGS. E8.10.32 & E8.10.33 FOR STAIRS NO.1, 2, 5, 6, 7 & 8 SECTIONS



108030700-E8E-8700-A038

Knight Jacobs
 Knight Jacobs Joint Venture
 701 Scoboro Road, MS 8203
 Oak Ridge, TN 37830
 865-241-9433
 Fax 865-241-3400

KNIGHT
 Knight Advanced Technology
 649 West Rutledge Street
 Chicago, IL 60601

UT-BATTELLE
 Oak Ridge National Laboratory
 managed for the DEPARTMENT OF ENERGY under
 U.S. GOVERNMENT CONTRACT DE-AC05-00OR22725
 UT-BATTELLE, LLC • Oak Ridge, Tennessee

PROJECT NAME:
SPALLATION NEUTRON SOURCE

TARGET BUILDING
 ELECTRICAL LIGHTING PLAN
 LEVEL B1, SECTOR 42

1	48	49	50	PLANT	BLDG	FL	SH.	OF	TYPE	CLASS
3	E	X	X	8	8700		1	1	P	U
51		52	53	WBS						
NC		NA		1.8.3.7					E3.B1.42	0

REV	DATE	DESCRIPTION	DSN	CHK	DEPT	DATE	REQ	DATE	UTB	DATE	RPE	RPE NO	DATE	ST	CV	EC	EE	EM	IE	M	PD	SE	AR	
0		CERTIFIED FOR CONSTRUCTION - 10/28/01	HG	VGS		10/28/01																		

REVISION APPROVALS

REVISIONS:

- 11/13/01 RPE W/notes
- 11/14/01 W/notes

NO REPRESENTATION OR WARRANTY, EXPRESSED OR IMPLIED, IS MADE AS TO THE ACCURACY, COMPLETENESS OR USEFULNESS OF THE INFORMATION OR STATEMENTS CONTAINED IN THESE DRAWINGS, OR THAT THE USE OR DISCLOSURE OF ANY INFORMATION, APPARATUS, METHOD, OR PROCESS DISCLOSED IN THESE DRAWINGS MAY NOT INFRINGE PRIVATE RIGHTS OF OTHERS. NO LIABILITY IS ASSUMED WITH RESPECT TO THE USE OF, OR FOR DAMAGES RESULTING FROM THE USE OF ANY INFORMATION, APPARATUS, METHOD, OR PROCESS DISCLOSED IN THESE DRAWINGS. DRAWINGS MADE AVAILABLE FOR INFORMATION TO BIDDER ARE NOT TO BE USED FOR OTHER PURPOSES AND ARE TO BE RETURNED UPON REQUEST OF THE FORWARDING CONTRACTOR.

THIS DOCUMENT CONTROLLED BY
 CHANGE CONTROL SYSTEM 3
 ENGINEERING PROCEDURE SNS-ENG-0001

SECTION AND DETAIL KEY

DRAWING ON WHICH SECTION OR DETAIL IS SHOWN OR TAKEN