


GENERAL NOTES:
 1. SEE DRAWINGS E9.21.52 AND E9.21.53 FOR LIGHTING PANEL SCHEDULES.
 2. SEE DRAWINGS E9.30.01 AND E9.30.02 FOR FIXTURE SCHEDULES.

KEYED NOTES:
 N001 ALL NORMAL LIGHTING FIXTURES ON THIS DRAWING WEST OF COLUMN LINE 9 ARE CIRCUITED FROM PANEL 30A LOCATED IN ELECTRICAL ROOM 3-3-80.
 N002 ALL NORMAL LIGHTING FIXTURES ON THIS DRAWING EAST OF COLUMN LINE 9 ARE CIRCUITED FROM PANEL 30A LOCATED IN ELECTRICAL ROOM 3-3-108.
 N003 ALL EMERGENCY LIGHTING FIXTURES AND EXIT SIGNS ON THIS DRAWING SOUTH OF COLUMN LINE J ARE CIRCUITED FROM PANEL 10A LOCATED IN ELECTRICAL ROOM 1-3-110.
 N004 ALL EMERGENCY LIGHTING FIXTURES AND EXIT SIGNS ON THIS DRAWING NORTH OF COLUMN LINE J ARE CIRCUITED FROM PANEL 10A LOCATED IN ELECTRICAL ROOM 1-4-127.
 N005 ALL FIXTURES ARE MOUNTED 9'-0" A.F.F. UNLESS OTHERWISE NOTED.
 N006 CORRIDOR FIXTURES (W1) ARE MOUNTED 8'-0" A.F.F.
 N007 LIGHTING FOR STAIRWAY No.'s 3 AND 4 ARE CIRCUITED FROM PANEL FROM PANEL 10A IN ELECTRICAL ROOM 1-4-127.



NO REPRESENTATION OR WARRANTY, EXPRESSED OR IMPLIED, IS MADE AS TO THE ACCURACY, COMPLETENESS OR USEFULNESS OF THE INFORMATION OR STATEMENTS CONTAINED IN THESE DRAWINGS, OR THAT THE USE OR DISCLOSURE OF ANY INFORMATION, APPARATUS, METHOD, OR PROCESS DISCLOSED IN THESE DRAWINGS MAY NOT INFRINGE PRIVATE RIGHTS OF OTHERS. NO LIABILITY IS ASSUMED WITH RESPECT TO THE USE OF, OR FOR DAMAGES RESULTING FROM THE USE OF ANY INFORMATION, APPARATUS, METHOD, OR PROCESS DISCLOSED IN THESE DRAWINGS. DRAWINGS MADE AVAILABLE FOR INFORMATION TO BIDDERS ARE NOT TO BE USED FOR OTHER PURPOSES AND ARE TO BE RETURNED UPON REQUEST OF THE FORMING CONTRACTOR.

THIS DOCUMENT CONTROLLED BY CHANGE CONTROL SYSTEM ENGINEERING PROCEDURE SNS-ENG-0001

SECTION AND DETAIL KEY

REV	DATE	DESCRIPTION	DSN	CHK	DEPT	DATE	PE	DATE	PE	DATE	REQ	DATE	UTB	DATE	RPE	RPE NO	DATE	ST	CV	EC	EE	EM	IE	M	PD	SE	AR	SQUAD CHECK	DRAWING APPROVALS
0		CERTIFIED FOR CONSTRUCTION - 12/20/01																											

DSN	T. WHITE	12/20/01
DRW	T. WHITE	12/20/01
CHK	K.SZOT	12/20/01
DEPT		
PE	<i>[Signature]</i>	12/17/01
PJ	<i>[Signature]</i>	12/17/01
REQ		

PROJECT NAME:
**SPALLATION NEUTRON SOURCE
 CENTRAL LAB AND OFFICE BUILDING
 ELECTRICAL LIGHTING PLAN
 LEVEL 03, SECTOR 63 - ALTERNATE #1A**

1	48	49	50	PLANT	BLDG	FL	SH.	OF	TYPE	CLASS
3	E	X	X	8	8600	1	1	1	P	U
51	NC	52	NA	53	WBS					
					1.8.3.14					E3.03.63.A1
										REV 0

108031400-E8E-8600-A182

KNIGHT
 Knight Advanced Technology
 701 Scoboro Road, MS 8253
 Oak Ridge, TN 37830
 865-241-9433
 fax 865-241-3400

UT-BATTELLE
 Oak Ridge National Laboratory
 managed for the DEPARTMENT OF ENERGY under
 U.S. GOVERNMENT contract DE-AC05-00OR22725
 UT-BATTELLE, LLC, a Oak Ridge, Tennessee

AutoCAD