Type V

XP-265-4-2L-C

Hazardous Locations • Paint Spray Booth • UL 844, 595 • Marine/Shipboard • CSA Certified • Factory Sealed

Catalog Number Logic

TYPE - V

XP1500-4-2L-A XX

(1) (2) (3) (4) (5) (6)

(1) BASIC SERIES

(i) XP FLUORESCENT FIXTURE
- Class I, Division 1, Group C and D
- Class I, Division 2, Group A, B, C and D
- Class II, Division 1 and 2, Group E, F and G
- Class III
- Simultaneous Presence
- Nema 3, 4X, 7CD, 9EFG: IP65
- UL 1570, 844, 924, 595
- CSA Approved
- Class I, Zone 1, Groups IIA and IIB
- Class I, Zone 2, Gourps IIA, IIB and IIC
- Suitable for inside paint spray booths

(ii) XPPL SERIES PORTABLE FLUORESCENT FIXTURE
- Class I, Division 1, Group C and D
- Class I, Division 2, Group A, B, C and D
- Class II, Division 1 and 2, Group E, F and G
- Class III
- Suitable for inside paint spray booths

(2) LAMP CURRENT/LAMP WATT

1500 = 1500 mA, 110 Watt
800 = 800 mA, 60 or 35 Watt
430 = 430 mA, 34 or 20 Watt
425 = 425 mA, 40, or 20 Watt (DC & Slimline)
265 = 265 mA, 17 or 32 Watt (T8 Lamp)
270 = 270 mA, 39 Watt (Biaxial Lamp)

(3) NOMINAL FIXTURE LENGTH

4 = 4 Foot
2 = 2 Foot

(4) NUMBER OF LAMPS

2L = 2 Lamps
3L = 3 Lamps
4L = 4 Lamps

(5) VOLTAGE/FREQUENCY

A = 120V 60HZ	E = 12V DC
B = 236V 60HZ	F = 24V DC
C = 277V 60HZ	G = 32V DC
D = 220V 50HZ	H = 347V 60HZ

(6) OPTIONS *

EL = Electronic Ballast
EM = Emergency Lighting w/ Battery Pack
F = Inline Fuse (External)
G = Stainless Steel Guard
S = Polycarbonate Shield
Z = 0° F Ballast**
(not available with EM options)
R = Radio Interference Filter

* Consult factory for pricing.
** Minimum starting temperature for standard 1500 mA & 800 mA fixtures is -20°F