AIR HANDLING UNIT SCHEDULE

UNIT NO.	SERVICE	LOCATION	FAN CAPACITY (CFM)	MINIMUM OUTSIDE AIR (CFM)	TOTAL S.P. IN. WG.	FAN DATA RPM	FAN DATA OUTLET VELOCITY	FAN DATA WHEEL DIAMETER (INCHES)	FAN DATA WHEEL TYPE	FAN DATA BHP	MOTOR DATA HP	MOTOR DATA VOLTS	MOTOR DATA PH	MOTOR DATA HZ	MOTOR DATA RPM	ACCESSORIES MIXING BOX	ACCESSORIES ACCESS SECTION	FILTER DATA BASED ON FARR MAX. FACE AREA VEL FPM	FILTER TYPE	EFFICIENCY %	NOMINAL OPERATING WEIGHT LBS.	TRANE BASIS OF DESIGN MODEL NO.	SYSTEM TYPE	REMARKS
AH-CL-1	SUBSTATION B2	B2-MECH. RM.	24000	24000	2.75	1148	2149	30	AF	15.9	20	460	3	60	1750	NO	1	438	12" CARTRIDGE SHORT BAG	65	4648	MCC-40	CONSTANT VOLUME	(2)(3)
AH-CL-2	ME SHOP	B1-MEZZANINE	4520	420	3.50	2644	1950	13.5	BI	4.3	5	460	3	60	1750	NO	2	429	12" CARTRIDGE SHORT BAG	65	1192	MCC-10	CONSTANT VOLUME	(2)(3)
AH-CL-3	POWER SHOP	B1-MEZZANINE	7190	240	3.75	2272	2118	16.5	BI	7.5	10	460	3	60	1750	YES	2	469	12" CARTRIDGE SHORT BAG	65	2663	MCC-14	CONSTANT VOLUME	(2)(3)
AH-CL-4	MAGNET SHOP	B1-MEZZANINE	8550	240	4.00	2057	2064	18.25	BI	9.2	10	460	3	60	1750	YES	2	493	12" CARTRIDGE SHORT BAG	65	3042	MCC-17	CONSTANT VOLUME	(2)(3)
AH-CL-5	GALLERY	AUDITORIUM MECH. RM.	11720	2700	6.00	1840	1862	22.25	BI	16.6	20	460	3	60	1750	YES	2	512	12" CARTRIDGE SHORT BAG	65	3879	MCC-25	VARIABLE AIR VOLUME	(1)(2)(3)
AH-CL-6	CAFETERIA	B1-MEZZANINE	6070	3800	5.00	2720	2176	15.0	BI	7.9	10	460	3	60	1750	YES	2	552	12" CARTRIDGE SHORT BAG	65	2388	MCC-12	VARIABLE AIR VOLUME	(1)(2)(3)
AH-CL-7	KITCHEN	B1-MEZZANINE	4330	4330	4.75	2821	1875	13.5	BI	5.2	7.5	460	3	60	1750	YES	2	466	12" CARTRIDGE SHORT BAG	65	2111	MCC-10	CONSTANT AIR VOLUME	(2)(3)
AH-CL-8	RING CAVITY	B1-MEZZANINE	5790	120	3.50	2426	2079	15.0	BI	5.7	7.5	460	3	60	1750	YES	2	555	12" CARTRIDGE SHORT BAG	65	2399	MCC-12	CONSTANT AIR VOLUME	(2)(3)
AH-CL-9	MATERIAL HANDLING	B1-MEZZANINE	3160	1000	4..50	2117	2257	10.5	FC	3.8	5	460	3	60	1750	YES	2	540	12" CARTRIDGE SHORT BAG	65	1423	MCC-8	CONSTANT AIR VOLUME	(2)(3)
AH-CL-10	LOCKER ROOM	B1-MEZZANINE	5850	4085	5.50	2345	1721	16.5	BI	8.0	10	460	3	60	1750	YES	2	435	12" CARTRIDGE SHORT BAG	65	2649	MCC-14	VARIABLE AIR VOLUME	(1)(2)(3)
AH-CL-11	VACUUM SHOP	VACUUM SHOP	9490	3000	4.00	2171	2294	18.25	BI	10.8	15	460	3	60	1750	YES	2	549	12" CARTRIDGE SHORT BAG	65	3037	MCC-21	CONSTANT AIR VOLUME	(2)(3)
AH-CL-12	CONTROL ROOM	VACUUM SHOP MEZZ.	6680	670	3.75	2193	1971	16.5	BI	6.7	7.5	460	3	60	1750	YES	2	456	12" CARTRIDGE SHORT BAG	65	2631	MCC-14	CONSTANT AIR VOLUME	(2)(3)
AH-CL-13	PLANT SHOP	B1-PLANT SHOP MEZZ.	7660	1400	5.25	2552	2220	16.5	BI	10.6	15	460	3	60	1750	YES	2	517	12" CARTRIDGE SHORT BAG	65	2736	MCC-17	VARIABLE AIR VOLUME	(1)(2)(3)
AH-CL-14	COMPUTER ROOM	COMPUTER ROOM	11770	200	0.5 ESP	–	–	–	–	–	7.5	460	3	60	1750	–	–	500	24x24 DISPOSABLE	65	1390	FH422CGI	LIEBERT DOWNFLOW	(2)(3)(5)(6)(7)(8)(9)(10)(11)
AH-CL-15	COMPUTER ROOM	COMPUTER ROOM	11770	200	0.5 ESP	–	–	–	–	–	7.5	460	3	60	1750	–	–	500	24X24 DISPOSABLE	65	1390	FH422CGI	LIEBERT DOWNFLOW	(2)(3)(5)(6)(7)(8)(9)(10)(11)
AH-CL-16	DRY LAB	LEVEL 3 MECH. RM.	31000	2420	6.75	1195	1889	36.5	AF	45.1	50	460	3	60	1750	YES	2	424	12" CARTRIDGE SHORT BAG	65	11365	MCC-66	VARIABLE AIR VOLUME	(1)(2)(3)
AH-CL-17	DRY LAB	LEVEL 3 MECH. RM.	31000	2420	6.75	1195	1889	36.5	AF	45.1	50	460	3	60	1750	YES	2	424	12" CARTRIDGE SHORT BAG	65	11365	MCC-66	VARIABLE AIR VOLUME	(1)(2)(3)
AH-CL-18	DRY LAB	LEVEL 3 MECH. RM.	31000	2420	6.75	1195	1889	36.5	AF	45.1	50	460	3	60	1750	YES	2	424	12" CARTRIDGE SHORT BAG	65	11365	MCC-66	VARIABLE AIR VOLUME	(1)(2)(3)
AH-CL-19	WET LAB	LEVEL 3 MECH. RM.	40000	38840	6.25	1199	2349	36.5	AF	51.0	60	460	3	60	1750	YES	2	496	12" CARTRIDGE SHORT BAG	65	13096	MCC-80	VARIABLE AIR VOLUME	(1)(2)(3)
AH-CL-20	WET LAB	LEVEL 3 MECH. RM.	40000	38840	6.25	1199	2349	36.5	AF	51.0	60	460	3	60	1750	YES	2	496	12" CARTRIDGE SHORT BAG	65	13096	MCC-80	VARIABLE AIR VOLUME	(1)(2)(3)
AH-CL-21	SUB-BASEMENT	B2-MECH. RM	2900	770	3.50	1862	1929	10.5	FC	2.6	5	460	3	60	1750	NO	2	429	12" CARTRIDGE SHORT BAG	65	1192	MCC-6	CONSTANT AIR VOLUME	(2)(3)
AH-CL-22	NORTH OFFICE WING	LEVEL 4 ROOF	24400	3160	4.75	1289	1969	30.0	AF	21.8	25	460	3	60	1750	NO	1	500	12" CARTRIDGE SHORT BAG	65	12775	TSCX-50	VARIABLE AIR VOLUME	(1)(2)(3)(4)
AH-CL-23	NORTH OFFICE WING-EAST	LEVEL 4 ROOF	18200	3800	5.00	1466	2011	27.0	AF	18.9	25	460	3	60	1750	NO	1	500	12" CARTRIDGE SHORT BAG	65	10404	TSCX-40	VARIABLE AIR VOLUME	(1)(2)(3)(4)
AH-CL-24	CONFERENCE ROOM L1	LEVEL 5 MECH. RM.	7650	2960	6.00	2649	2250	16.5	BI	11.8	15	460	3	60	1750	YES	2	514	12" CARTRIDGE SHORT BAG	65	2743	MCC-17	VARIABLE AIR VOLUME	(1)(2)(3)
AH-CL-25	OFFICE ATRIUM	LEVEL 5 MECH. RM.	15000	1000	4.25	1825	2381	22.25	BI	17.3	25	460	3	60	1750	YES	2	536	12" CARTRIDGE SHORT BAG	65	4271	MCC-30	CONSTANT AIR VOLUME	(2)(3)
AH-CL-26	AUDITORIUM	AUDITORIUM MECH. RM.	9200	5250	4.25	1785	1746	20.0	BI	9.4	15	460	3	60	1750	YES	2	418	12" CARTRIDGE SHORT BAG	65	3397	MCC-21	CONSTANT AIR VOLUME	(2)(3)
AH-CL-27	LOBBY	B1-GALLERY	33200	1000	4.50	791	2017	52.88	AF	37.5	50	460	3	60	1750	YES	2	453	12" CARTRIDGE SHORT BAG	65	11343	MCC-66	CONSTANT AIR VOLUME	(2)(3) PLUG FAN
AH-CL-28	LEVEL 5 OFFICE	LEVEL 5 MECH. RM.	9320	1980	5.25	1950	1849	20.0	BI	12.2	15	460	3	60	1750	YES	2	414	12" CARTRIDGE SHORT BAG	65	3385	MCC-21	VARIABLE AIR VOLUME	(1)(2)(3)
AH-CL-29	LEVEL 4 OFFICE	LEVEL 5 MECH. RM.	24950	2820	6.25	1473	2234	30	AF	32.4	40	460	3	60	1750	YES	2	453	12" CARTRIDGE SHORT BAG	65	7947	MCC-50	VARIABLE AIR VOLUME	(1)(2)(3)
AH-CL-30	LEVEL 3 OFFICE	LEVEL 5 MECH. RM.	12620	2800	6.00	1876	2003	22.25	BI	18.0	25	460	3	60	1750	YES	2	515	12" CARTRIDGE SHORT BAG	65	3885	MCC-25	VARIABLE AIR VOLUME	(1)(2)(3)
AH-CL-31	LEVEL 2 OFFICE	LEVEL 5 MECH. RM.	12740	2730	6.00	1882	2022	22.25	BI	18.2	25	460	3	60	1750	YES	2	472	12" CARTRIDGE SHORT BAG	65	3868	MCC-25	VARIABLE AIR VOLUME	(1)(2)(3)
AH-CL-32	LEVEL 1 OFFICE	LEVEL 5 MECH. RM.	5740	1700	5.75	2769	2058	15.0	BI	8.3	10	460	3	60	1750	YES	2	540	12" CARTRIDGE SHORT BAG	65	2387	MCC-12	VARIABLE AIR VOLUME	(1)(2)(3)
AH-CL-33	KITCHEN HOOD MUA	B1-MEZZANINE	4330	4330	4.75	2821	1875	13.5	BI	5.2	7.5	460	3	60	1750	YES	2	466	12" CARTRIDGE SHORT BAG	65	2111	MCC-10	CONSTANT AIR VOLUME	(2)(3)

KEY TO REMARKS

1. VARIABLE FREQUENCY DRIVE WITH MANUAL BYPASS
2. VIBRATION ISOLATION TO BE SPRING TYPE, 2" MIN. DEFLECTION
3. FARR 30/30 PRE-FILTER
4. OUTDOOR DAMPER WITH WEATHER COVER
5. 12" DEEP CARTRIDGE FILTER, 65% EFFICIENCY
6. LEAK DETECTION UNDER UNIT, IN 4" HIGH DRAIN PAN
7. FIRESTAT
8. DOWNFLOW ARRANGEMENT W/ FLOOR STAND
9. SMOKE DETECTION
10. CONDENSATE PUMP
11. DISCONNECT SWITCH

FAN SCHEDULE

UNIT No.	SERVICE	FAN CAPACITY (CFM)	STATIC PRESS. (IN.WG)	FAN TYPE	FAN SPEED (RPM)	WHEEL DIA. (INCH)	DRIVE	BHP	MOTOR ELECTRICAL DATA HP	VOLTS	PH	HZ	RPM	BASIS OF DESIGN MFR.	MODEL No.	REMARKS	
RF-CL-1	AH - CL -10	1915	1.5	VANE AXIAL	1955	16	BELT	0.784	1	460	3	60	1750	TRANE	Q-16	RETURN FAN - LOCKER ROOMS	(3)(4)(5)(16)
RF-CL-2	AH - CL - 16	30590	1.5	VANE AXIAL	1043	44	BELT	14.38	15	460	3	60	1750	TRANE	Q-44	RETURN FAN - DRY LAB	(3)(4)(5)(16)
RF-CL-3	AH - CL - 17	30590	1.5	VANE AXIAL	1043	44	BELT	14.38	15	460	3	60	1750	TRANE	Q-44	RETURN FAN - DRY LAB	(3)(4)(5)(16)
RF-CL-4	AH - CL - 18	30590	1.5	VANE AXIAL	1043	44	BELT	14.38	15	460	3	60	1750	TRANE	Q-44	RETURN FAN - DRY LAB (STAND BY)	(3)(4)(5)(16)
RF-CL-5	AH - CL - 12	6030	1.5	VANE AXIAL	1122	27	BELT	2.02	3	460	3	60	1750	TRANE	Q-27	CONTROL ROOM	(3)(4)(5)
RF-CL-6	AH - CL - 24	5595	1.5	VANE AXIAL	1084	27	BELT	1.84	2	460	3	60	1750	TRANE	Q-27	RETURN FAN - CONFERENCE ROOM	(3)(4)(5)(16)
RF-CL-7	AH - CL - 25	14000	1.5	VANE AXIAL	1231	33	BELT	5.67	7.5	460	3	60	1750	TRANE	Q-33	RETURN FAN - OFFICE ATRIUM	(3)(4)(5)
RF-CL-8	AH - CL - 26	8800	1.5	VANE AXIAL	1407	27	BELT	3.58	5	460	3	60	1750	TRANE	Q-27	RETURN FAN - AUDITORIUM	(3)(4)(5)
RF-CL-9	AH - CL - 27	32200	1.5	VANE AXIAL	1088	44	BELT	15.96	20	460	3	60	1750	TRANE	Q-44	RETURN FAN - LOBBY	(3)(4)(5)
RF-CL-10	AH - CL - 28	7400	1.5	VANE AXIAL	1255	27	BELT	2.67	3	460	3	60	1750	TRANE	Q-27	RETURN FAN - LEVEL 5	(3)(4)(5)(16)
RF-CL-11	AH - CL - 29	22020	1.5	VANE AXIAL	1051	40	BELT	9.29	10	460	3	60	1750	TRANE	Q-40	RETURN FAN - LEVEL 4	(3)(4)(5)(16)
RF-CL-12	AH - CL - 30	9560	1.5	VANE AXIAL	1161	30	BELT	3.56	5	460	3	60	1750	TRANE	Q-30	RETURN FAN - LEVEL 3	(3)(4)(5)(16)
RF-CL-13	AH - CL - 31	8610	1.5	VANE AXIAL	1090	30	BELT	3.02	5	460	3	60	1750	TRANE	Q-30	RETURN FAN - LEVEL 2	(3)(4)(5)(16)
RF-CL-14	AH - CL - 32	3700	1.5	VANE AXIAL	1115	24	BELT	1.23	1.5	460	3	60	1750	TRANE	Q-24	RETURN FAN - LEVEL 1	(3)(4)(5)(16)
RF-CL-15	AH - CL - 5	9970	1.5	VANE AXIAL	1193	30	BELT	3.81	5.0	460	3	60	1750	TRANE	Q-30	B1 - 1 GALLERY	(3)(4)(5)(16)
RF-CL-16	AH - CL - 6	1580	1.5	VANE AXIAL	1777	16	BELT	0.61	1	460	3	60	1750	TRANE	Q-16	CAFE	(3)(4)(5)(16)
RF-CL-19	AH - CL - 23	14900	1.5	CENTRIFUGAL	534	30 1/4	BELT	10.047	15	460	3	60	1750	TRANE	40A 30 1/4	RETURN FAN - N OFF WING EAST	(3)(4)(5)(16) FURNISHED WITH AHU
RF-CL-20	AH - CL - 22	21510	1.5	CENTRIFUGAL	485	33	BELT	13.9	15	460	3	60	1750	TRANE	50A 33	RETURN FAN - N OFF WING	(3)(4)(5)(16) FURNISHED WITH AHU
SEF-CL-1	OFFICE ATRIUM	20000	1.5	CENTRIFUGAL	761	36	BELT	7.25	15	460	3	60	1750	GREENHECK	SWB-36	SMOKE EXHAUST FAN	(3)(4)(5)(7)(12)(13)
SEF-CL-2	OFFICE ATRIUM	20000	1.5	CENTRIFUGAL	761	36	BELT	7.25	15	460	3	60	1750	GREENHECK	SWB-36	SMOKE EXHAUST FAN	(3)(4)(5)(7)(12)(13)
SEF-CL-3	OFFICE ATRIUM	20000	1.5	CENTRIFUGAL	761	36	BELT	7.25	15	460	3	60	1750	GREENHECK	SWB-36	SMOKE EXHAUST FAN	(3)(4)(5)(7)(12)(13)
SEF-CL-4	OFFICE ATRIUM	20000	1.5	CENTRIFUGAL	761	36	BELT	7.25	15	460	3	60	1750	GREENHECK	SWB-36	SMOKE EXHAUST FAN	(3)(4)(5)(7)(12)(13)
SEF-CL-5	LOBBY	23000	1.5	CENTRIFUGAL	976	36	BELT	14.6	15	460	3	60	1750	GREENHECK	SWB-36	SMOKE EXHAUST FAN	(3)(4)(5)(7)(12)(13)
SEF-CL-6	LOBBY	23000	1.5	CENTRIFUGAL	976	36	BELT	14.6	15	460	3	60	1750	GREENHECK	SWB-36	SMOKE EXHAUST FAN	(3)(4)(5)(7)(12)(13)
SMF-CL-1	OFFICE ATRIUM	23000	1.5	CENTRIFUGAL	976	36	BELT	14.6	15	460	3	60	1750	GREENHECK	SWB-36	MAKE UP AIR FAN	(3)(4)(5)(7)(12)
SMF-CL-2	OFFICE ATRIUM	23000	1.5	CENTRIFUGAL	976	36	BELT	14.6	15	460	3	60	1750	GREENHECK	SWB-36	MAKE UP AIR FAN	(3)(4)(5)(7)(12)
SMF-CL-3	LOBBY	22000	1.5	VANE AXIAL	1051	40	BELT	9.29	10	460	3	60	1750	TRANE	Q-40	MAKE UP AIR FAN	(3)(4)(5)(7)
SMF-CL-4	LOBBY	22000	1.5	VANE AXIAL	1051	40	BELT	9.29	10	460	3	60	1750	TRANE	Q-40	MAKE UP AIR FAN	(3)(4)(5)(7)
EF-CL-1	AH - CL - 19	42920	1.5	CENTRIFUGAL	1050	49	BELT	24.9	30	460	3	60	1750	TRANE	Q-49	WET LAB EXHAUST	(1)(3)(4)(16)
EF-CL-2	AH - CL - 20	42920	1.5	CENTRIFUGAL	1050	49	BELT	24.9	30	460	3	60	1750	TRANE	Q-49	WET LAB EXHAUST (STAND BY)	(1)(3)(4)(16)
EF-CL-3	AH - CL - 1	24000	0.75	VANE AXIAL	1117	42	BELT	7.22	7.5	460	3	60	1750	COOLAIR	TEBC42R		(2)(3)(4)(7)(13)(14)(15)
EF-CL-4	AH - CL - 21	750	0.75	PROPELLER	1750	12	DIRECT	.23	0.33	120	1	60	1750	COOLAIR	UDU12H17		(2)(3)(4)(7)(13)(14)(15)
EF-CL-5	TOILET STACK	5420	1.5	CENT. - UPBLAST	1180	22	BELT	2.66	3	460	3	60	1750	GREENHECK	CUBE-220HP-30		(3)(4)(6)(8)(9)(11)(12)(13)(14)(15)
EF-CL-6	AH - CL - 13	3500 / 7000	0.5	PROPELLER	546 / 832	24	BELT	1.26	2	460	3	60	1150/1750	COOLAIR	CBH30N-S24		(3)(4)(6)(8)(9)(11)(12)(13)(14)(15)(16)
EF-CL-7	TOILET STACK	2560	1.5	CENT. - UPBLAST	1335	18	BELT	1.04	2	460	3	60	1750	GREENHECK	CUBE-180HP-10		(3)(4)(7)(13)(14)(15)
EF-CL-8	AH - CL - 2	420 - 4200	1.5	CENTRIFUGAL	2 - SPEED	21	BELT	1.483	2	460	3	60	1150/1750	TRANE	Q-21	MECH. SHOP	(3)(4)(7)(13)(14)(15)
EF-CL-9	AH - CL - 11	6000 / 9160	0.5	PROPELLER	610 / 920	30	BELT	2.31	3	460	3	60	1150/1750	COOLAIR	CBH30N-S30		(3)(4)(7)(13)(14)(15)
EF-CL-10	AH - CL - 3	4500 / 6900	0.5	PROPELLER	546 / 832	24	BELT	1.26	2	460	3	60	1150/1750	COOLAIR	CBH30N-S24		(3)(4)(7)(13)(14)(15)
EF-CL-11	AH - CL - 9	1000	0.5	PROPELLER	1750	14	DIRECT	.23	0.33	120	1	60	1750	COOLAIR	UDU14F17-S14		(3)(4)(7)(13)(14)(15)
EF-CL-12	TOILET STACK	7685	1.5	CENT. - UPBLAST	1045	30	BELT	3.93	5	460	3	60	1750	GREENHECK	CUBE-300HP-50		(3)(4)(6)(7)(8)(9)(11)(12)(13)(14)(15)
EF-CL-13	JANITORS CLOSET	5550	1.5	CENT. - UPBLAST	1180	22	BELT	2.66	3	460	3	60	1750	GREENHECK	CUBE-300HP-30		(3)(4)(6)(8)(9)(11)(12)(13)(14)(15)
EF-CL-14	AH - CL - 4	5400 - 8240	0.5	PROPELLER	546 / 832	30	BELT	1.77	2	460	3	60	1150/1750	COOLAIR	CBH30M-S30		(3)(4)(7)(13)(14)(15)
EF-CL-15	AH - CL - 8	1295	0.5	PROPELLER	1750	14	DIRECT	.23	0.33	120	1	60	1150/1750	COOLAIR	UDU14F17-S14		(3)(4)(7)(13)(14)(15)
EF-CL-16	AH - CL - 9	0 - 2025	0.5	PROPELLER	1750	18	DIRECT	.38	0.5	460	3	60	1150/1750	COOLAIR	CDC18H17-SU18		(3)(4)(7)(13)(14)(15)
EF-CL-17	AH - CL - 7	7965	1.5	CENT. - UPBLAST	1045	30	BELT	3.93	5	460	3	60	1750	GREENHECK	CUBE-300HP-50	GREASE TRAP BIRD SCREEN	(3)(4)(6)(8)(9)(10)(11)(12)(13)(14)(15)
EF-CL-18	AH-CL-16,17 & 18	15000	1.5	SWSI CENTRIF	1100	30	BELT	6.75	7.5	460	3	60	1750	GREENHECK	30AFSW	SCAVENGER EXHAUST - DRY LABS	(1)(3)(4) ARR 10, UPBLAST

KEY TO REMARKS

1. BAKED PHENOLIC (HERESITE COATING INSIDE FAN)
2. INLET BELL
3. INLET AND OUTLET FLANGES
4. SPRING AND NEOPRENE ISOLATORS
5. ACCESS DOOR MOTOR SIDE
6. DRAIN CONNECTION
7. INLET SCREEN
8. RIGID WIRE BIRD SCREEN
9. HINGING FOR ACCESS
10. GREASE TRAP
11. NEMA 3R WEATHERPROOF DISCONNECT SWITCH
12. PREFABRICATED ROOF CURB WITH LEVEL TOP
13. BACKDRAFT DAMPER
14. FAN GUARD
15. WALL HOUSING/SLEEVE
16. VARIABLE FREQUENCY DRIVE WITH MANUAL BYPASS

NO REPRESENTATION OR WARRANTY, EXPRESSED OR IMPLIED, IS MADE AS TO THE ACCURACY, COMPLETENESS OR USEFULNESS OF THE INFORMATION OR STATEMENTS CONTAINED IN THESE DRAWINGS, OR THAT THE USE OR DISCLOSURE OF ANY INFORMATION, APPARATUS, METHOD, OR PROCESS DISCLOSED IN THESE DRAWINGS MAY NOT INFRINGE PRIVATE RIGHTS OF OTHERS. NO LIABILITY IS ASSUMED WITH RESPECT TO THE USE OF, OR FOR DAMAGES RESULTING FROM THE USE OF ANY INFORMATION, APPARATUS, METHOD, OR PROCESS DISCLOSED IN THESE DRAWINGS. DRAWINGS MADE AVAILABLE FOR INFORMATION TO BIDDER ARE NOT TO BE USED FOR OTHER PURPOSES AND ARE TO BE RETURNED UPON REQUEST OF THE FORWARDING CONTRACTOR.

SECTION AND DETAIL KEY: NUMBER OF SECTION OR DETAIL / DRAWING ON WHICH SECTION OR DETAIL IS SHOWN OR TAKEN

THIS DOCUMENT CONTROLLED BY CHANGE CONTROL SYSTEM 4
ENGINEERING PROCEDURE SNS-ENG-G001

REV	CHANGE TYPE	CHANGE CONTROL SYSTEM	CHANGE REQUEST NUMBER	DESCRIPTION	DSN	CHK	DEPT	DATE	PE	DATE	PJ	DATE	REQ	DATE	UTB	DATE	RPE	RPE NO	DATE	ST	CV	EC	EE	EM	IE	M	PD	SE	AR
1				CERTIFIED FOR CONSTRUCTION - 12/20/01	RTW	KJH			CJD	12/01	JS	12/01			JRL	12/20/01	BWJ	105869	12/20/01	RW	AW	BWJ	PD	BWJ	BWJ	--	BWJ	--	ED
0				CERTIFIED FOR CONSTRUCTION - MAY 15, 2001	RTW	KJH			CLG	9/6/01	JS	8/21/01			JRL	9/25/01	BWJ	105869	5/15/01	SC	AW	WRS	RL	WRS	BWJ	--	WRS	--	WAS

REVISION OR ISSUE PURPOSE — REVISION APPROVALS — SQUAD CHECK

DRAWING APPROVALS: RPE; DSN M. ECKERT 05/15/01; DRW R. WATSON 05/15/01; CHK B. JOHNSON 05/15/01; DEPT; PE C.L. GARREN 9/6/01; PJ J. STELLERN 08/21/01; REQ; UTB J.R. LAWSON 09/25/01
REV. 1 DATE 12/20/01

Seal: BRUCE W. JOHNSON REGISTERED ENGINEER No. 0010586 STATE OF TENNESSEE AGRICULTURE COMMERCE

108031400-H8E-8600-A094

Knight/Jacobs Joint Venture
701 Scarboro Road, MS 8253
Oak Ridge, TN 37830
865-241-9433
fax 865-241-3400

KNIGHT
Knight Advanced Technology
549 West Randolph Street
Chicago, IL 60661

UT-BATTELLE
Oak Ridge National Laboratory
managed for the DEPARTMENT OF ENERGY under U.S. GOVERNMENT contract DE-AC05-000R22725
UT-BATTELLE, LLC, © Oak Ridge, Tennessee

PROJECT NAME: SPALLATION NEUTRON SOURCE

CENTRAL LAB AND OFFICE BUILDING SCHEDULES HVAC

1	48	49	50	PLANT	BLDG	FL	SH.	OF	TYPE	CLASS
3	H	X	X	8	8600		1	1	G	U
51 NC	52 NA	53			WBS 1.8.3.14	H9.10.40			REV 1	

Date: 12/13/2001 Time: 18:10:13 Username: WATSONRT CHI-F_VOL2:PROJECTS\7000\700_CADD\TASK_2B\740_PLOT\H9-10-40.DWG