GENERAL NOTES:

1. SEE DRAWINGS E9.21.52 AND E9.21.53 FOR LIGHTING PANEL SCHEDULES.
2. SEE DRAWINGS E9.30.01 AND E9.30.02 FOR FIXTURE SCHEDULES.

KEYED NOTES:

N001 ALL NORMAL LIGHTING FIXTURES ON THIS DRAWING ARE CIRCUITED FROM PANEL 1L5A LOCATED IN ELECTRICAL ROOM 1-3-75.

N002 ALL EMERGENCY LIGHTING FIXTURES AND EXIT SIGNS ON THIS DRAWING ARE CIRCUITED FROM PANEL 1E1A LOCATED IN ELECTRICAL ROOM 1-4-127. LIGHTING IN STAIR NO. 2 TO BE CIRCUITED FROM PANEL B1E5A IN ELECTRICAL ROOM B1-2-31.

N003 ALL FIXTURES ARE MOUNTED 9'-6" A.F.F UNLESS OTHERWISE NOTED.

N004 CORRIDOR FIXTURES (W1) ARE MOUNTED 8'-0" A.F.F

N005 FIXTURES FOR ROOM 1-4-122 SHOWN ON E3.02.64.

N006 ALL FIXTURES DESIGNATED WITH LETTERS ONLY IN ROOM 1-4-122 ARE CIRCUITED FROM SCHILLER & SHOOK DIMMING RACKS. SEE CONTROL SCHEDULES ON DRAWING E9.21.54.

N007 ALL FIXTURES ARE MOUNTED APPROXIMATELY 15'-4" A.F.F. AND ARE MOUNTED UNDER LIGHT SHELF.





108031400-E8E-8600-A022

Knight Jacobs

Knight\Jacobs Joint Venture
701 Scarboro Road, MS 8253
Oak Ridge, TN 37830
865-241-9433
fax 865-241-3400

KNIGHT
Knight Advanced Technology
540 West Randolph Street
Chicago, IL 60661

UT-BATTELLE

Oak Ridge National Laboratory
managed for the DEPARTMENT OF ENERGY under
U.S. GOVERNMENT contract DE-AC05-00OR22725
UT-BATTELLE, LLC. ◆ Oak Ridge, Tennessee

PROJECT NAME:
SPALLATION NEUTRON SOURCE
CENTRAL LAB AND OFFICE BUILDING
ELECTRICAL LIGHTING PLAN
LEVEL 01, SECTOR 64

1	48	49	50	PLANT	BLDG	FL	SH.	OF	TYPE	CLASS
3	E	X	X	8	8600		1	1	P	U

51	52	53	WBS		REV
NC	NA		1.8.3.14	E3.01.64	0

DSN	T. WHITE	5/15/01
DRW	T. WHITE	5/15/01
CHK	K.SZOT	5/15/01
DEPT		
PE		10/8/01
PJ		10/8/01
REQ		
UTB		10/8/01

RPE: VICTOR G. STEFFEN, REGISTERED ENGINEER, No. 0015695, STATE OF TENNESSEE

0 5-10-01
REV. DATE
DRAWING APPROVALS

REV	CHANGE TYPE	CHANGE CONTROL SYSTEM	CHANGE ENGINEER NUMBER	DESCRIPTION	DSN	CHK	DEPT	DATE	PE	DATE	PJ	DATE	REQ	DATE	UTB	DATE	RPE	RPE NO	DATE
0				CERTIFIED FOR CONSTRUCTION – 5/15/01	TLW	KJS											VGS	106009	5/15/01

REVISION OR ISSUE PURPOSE — REVISION APPROVALS

SC	AW	BS	RL	BS	BJ	--	BS	--	WS
ST	CV	EC	EE	EM	IE	M	PD	SE	AR

SQUAD CHECK

NO REPRESENTATION OR WARRANTY, EXPRESSED OR IMPLIED, IS MADE AS TO THE ACCURACY, COMPLETENESS OR USEFULNESS OF THE INFORMATION OR STATEMENTS CONTAINED IN THESE DRAWINGS, OR THAT THE USE OR DISCLOSURE OF ANY INFORMATION, APPARATUS, METHOD, OR PROCESS DISCLOSED IN THESE DRAWINGS MAY NOT INFRINGE PRIVATE RIGHTS OF OTHERS. NO LIABILITY IS ASSUMED WITH RESPECT TO THE USE OF, OR FOR DAMAGES RESULTING FROM THE USE OF ANY INFORMATION, APPARATUS, METHOD, OR PROCESS DISCLOSED IN THESE DRAWINGS. DRAWINGS MADE AVAILABLE FOR INFORMATION TO BIDDERS ARE NOT TO BE USED FOR OTHER PURPOSES AND ARE TO BE RETURNED UPON REQUEST OF THE FORWARDING CONTRACTOR.

NUMBER OF SECTION OR DETAIL
DRAWING ON WHICH SECTION OR DETAIL IS SHOWN OR TAKEN
SECTION AND DETAIL KEY

THIS DOCUMENT CONTROLLED BY
CHANGE CONTROL SYSTEM 4
ENGINEERING PROCEDURE SNS-ENG-G001

AutoCAD
10/08/2001 Time: 13:17:22
Original Width: 60.00 in.
C:\ACLPROJECTS\SNS\SQ_CAD\E\DWG_E8\F40_FLOF\E3-01-64.DWG