


**GENERAL NOTES:**

- SEE DRAWINGS E9.21.52 AND E9.21.53 FOR LIGHTING PANEL SCHEDULES.
- SEE DRAWINGS E9.30.01 AND E9.30.02 FOR FIXTURE SCHEDULES.

**KEYED NOTES:**

- N001** ALL NORMAL LIGHTING FIXTURES ON THIS DRAWING ARE CIRCUITED FROM PANEL 35EA LOCATED IN ELECTRICAL ROOM 3-3-20.
- N002** ALL EMERGENCY LIGHTING FIXTURES AND EXIT SIGNS ON THIS DRAWING ARE CIRCUITED FROM PANEL 35EA LOCATED IN ELECTRICAL ROOM 3-2-86. LIGHTING IN STAR NO. 2 TO BE CIRCUITED FROM PANEL 35EA IN ELECTRICAL ROOM 81-2-31.
- N003** ALL FIXTURES ARE MOUNTED 9'-0" A.F.F. UNLESS OTHERWISE NOTED.
- N004** OUTSIDE PERIMETER LIGHTING FIXTURES ARE MOUNTED 7'-0" BELOW SOFFIT.
- N005** CORRIDOR FIXTURES (W1) ARE MOUNTED 8'-0" A.F.F.
- N006** AUDITORIUM LOBBY LIGHTING (SQ) MOUNTING HEIGHT IS 8'-0" DOWN FROM FINISHED CEILING.
- N007** LOBBY ACCENT LIGHTING MOUNTED IN LEDGES APPROXIMATELY 7'-0" BELOW BASIC CEILING.
- N008** FOR AUDITORIUM LOBBY LIGHT SWITCHING, SEE ELECT. RM. 1-1-22 ON DWG. E3.01.61.
- N009** ATRIUM LIGHTING TRACK TO BE MOUNTED TO SKYLIGHT SUPPORTS.
- N010** FOR LIGHTING CONTACTOR WIRING DIAGRAM, SEE E3.82.62.
- N011** CIRCUIT OUTSIDE PERIMETER LIGHTING FIXTURES VIA LIGHTING CONTACTOR LCP 3-61 (CIRCUITS 9, 11) IN ELECT. RM. 3-1-4.
- N012** FIXTURE SJ IS MOUNTED 7'-0" ABOVE CATWALK.




108031400-E8E-8600-A029

	Knight Jacobs Joint Venture 701 Scarboro Road, MS 8253 Oak Ridge, TN 37830 865-241-9433 Fax 865-241-3400	<b>KNIGHT</b> Knight Advanced Technology 400 West Main Street Oak Ridge, TN 37830
--	--	--

**UT-BATTELLE** Oak Ridge National Laboratory  
managed for the DEPARTMENT OF ENERGY under  
U.S. GOVERNMENT CONTRACT DE-AC05-00OR22725  
101-BATTELLE, LLC - Oak Ridge, Tennessee

PROJECT NAME:  
**CENTRAL LAB AND OFFICE BUILDING  
ELECTRICAL LIGHTING PLAN  
LEVEL 03, SECTOR 61**



DSN	C.SAPLALA	5/15/01
DRW	C.SAPLALA	5/15/01
CHK	K.SZOT	5/15/01
DEPT		
PE	C.L. GARREN	9/6/01
PJ	J. STELLERN	8/21/01
REQ		

REV	DATE	BY	DESCRIPTION
1	12-17-01	J.R. LAWSON	REVISED FOR CONSTRUCTION

REV	DATE	BY	DESCRIPTION
1	12-17-01	J.R. LAWSON	REVISED FOR CONSTRUCTION

REV	DATE	BY	DESCRIPTION	DSN	CHK	DEPT	DATE	PE	DATE	PJ	DATE	REQ	DATE	UTB	DATE	RPE	RPE NO	DATE
0			CERTIFIED FOR CONSTRUCTION - 12/20/01															
1			CERTIFIED FOR CONSTRUCTION - 5/15/01															

NO REPRESENTATION OR WARRANTY, EXPRESSED OR IMPLIED, IS MADE AS TO THE ACCURACY, COMPLETENESS OR USEFULNESS OF THE INFORMATION OR STATEMENTS CONTAINED IN THESE DRAWINGS, OR THAT THE USE OR DISCLOSURE OF ANY INFORMATION, APPARATUS, METHOD, OR PROCESS DISCLOSED IN THESE DRAWINGS MAY NOT INFRINGE, PRIVATE RIGHTS OF OTHERS. NO LIABILITY IS ASSUMED WITH RESPECT TO THE USE OF, OR FOR DAMAGES RESULTING FROM THE USE OF ANY INFORMATION, APPARATUS, METHOD, OR PROCESS DISCLOSED IN THESE DRAWINGS. DRAWINGS MADE AVAILABLE FOR INFORMATION TO BIDDERS ARE NOT TO BE USED FOR OTHER PURPOSES AND ARE TO BE RETURNED UPON REQUEST OF THE FORMING CONTRACTOR.

THIS DOCUMENT CONTROLLED BY  
CHANGE CONTROL SYSTEM  
ENGINEERING PROCEDURE SNS-ENG-0001

SECTION AND DETAIL KEY