


GENERAL NOTES:
 1. SEE DRAWINGS E9.21.52 AND E9.21.53 FOR LIGHTING PANEL SCHEDULES.
 2. SEE DRAWINGS E9.30.01 AND E9.30.02 FOR FIXTURE SCHEDULES.

KEYED NOTES:
 N001 ALL NORMAL LIGHTING FIXTURES ON THIS DRAWING ARE CIRCUITED FROM PANEL 4L2A LOCATED IN ELECTRICAL ROOM 4-1-41.
 N002 ALL EMERGENCY LIGHTING FIXTURES AND EXIT SIGNS ON THIS DRAWING ARE CIRCUITED FROM PANEL 3E5A LOCATED IN ELECTRICAL ROOM 3-2-56. LIGHTING IN STAIR NO. 2 TO BE CIRCUITED FROM PANEL 3E5A IN ELECTRICAL ROOM 3-2-31.
 N003 ALL FIXTURES ARE MOUNTED 9'-0" A.F.F. UNLESS OTHERWISE NOTED.
 N004 CORRIDOR FIXTURES (W1) ARE MOUNTED 8'-0" A.F.F.



NO REPRESENTATION OR WARRANTY, EXPRESSED OR IMPLIED, IS MADE AS TO THE ACCURACY, COMPLETENESS OR USEFULNESS OF THE INFORMATION OR STATEMENTS CONTAINED IN THESE DRAWINGS, OR THAT THE USE OR DISCLOSURE OF ANY INFORMATION, APPARATUS, METHOD, OR PROCESS DISCLOSED IN THESE DRAWINGS MAY NOT INFRINGE PRIVATE RIGHTS OF OTHERS. NO LIABILITY IS ASSUMED WITH RESPECT TO THE USE OF, OR FOR DAMAGES RESULTING FROM THE USE OF ANY INFORMATION, APPARATUS, METHOD, OR PROCESS DISCLOSED IN THESE DRAWINGS. DRAWINGS MADE AVAILABLE FOR INFORMATION TO BIDDERS ARE NOT TO BE USED FOR OTHER PURPOSES AND ARE TO BE RETURNED UPON REQUEST OF THE FORWARDING CONTRACTOR.

SECTION AND DETAIL KEY

THIS DOCUMENT CONTROLLED BY
 CHANGE CONTROL SYSTEM 4
 ENGINEERING PROCEDURE SNS-ENG-0001

REV	DATE	DESCRIPTION	DSN	CHK	DEPT	PE	DATE	PJ	DATE	REQ	DATE	UTB	DATE	RPE	RPE NO	DATE
0		CERTIFIED FOR CONSTRUCTION - 5/15/01														
1	5/15/01															

RPE
 DSN C.SAPALA 5/15/01
 DRW C.SAPALA 5/15/01
 CHK K.SZOT 5/15/01
 DEPT
 PE
 PJ
 REQ

1 4B 49 SO PLANT BLDG FL SH OF TYPE CLASS
 3 E X X 8 8600 1 1 P U
 51 52 53 WBS 1.8.3.14 E3.04.61 0
 NC NA

108031400-E8E-8600-A034

KNIGHT
 Knight Advanced Technology
 549 West Shavano Street
 Chicago, IL 60605

UT-BATTELLE
 managed for the DEPARTMENT OF ENERGY under
 U.S. GOVERNMENT contract DE-AC05-00OR22725
 UT-BATTELLE, LLC • Oak Ridge, Tennessee

PROJECT NAME:
**SPALLATION NEUTRON SOURCE
 CENTRAL LAB AND OFFICE BUILDING
 ELECTRICAL LIGHTING PLAN
 LEVEL 04, SECTOR 61**