



GENERAL NOTES:

- 1. SEE DRAWINGS E9.21.52 AND E9.21.53 FOR LIGHTING PANEL SCHEDULES.
- 2. SEE DRAWINGS E9.30.01 AND E9.30.02 FOR FIXTURE SCHEDULES.

KEYED NOTES:

- NO01** ALL NORMAL LIGHTING FIXTURES ON THIS DRAWING ARE CIRCUITED FROM PANEL S12A LOCATED IN ELECTRICAL ROOM 5-1-10.
- NO02** ALL EMERGENCY LIGHTING FIXTURES AND EXIT SIGNS ON THIS DRAWING ARE CIRCUITED FROM PANEL B25A LOCATED IN ELECTRICAL ROOM 3-2-66. LIGHTING IN STAIR NO. 2 TO BE CIRCUITED FROM PANEL B155A IN ELECTRICAL ROOM B1-2-31.
- NO03** ALL FIXTURES ARE MOUNTED 9'-5" A.F.F. UNLESS OTHERWISE NOTED.
- NO04** CORRIDOR FIXTURES (W1) ARE MOUNTED 12'-7" A.F.F.
- NO05** FOR LIGHTING CONTACTOR WIRING DIAGRAM, SEE E3.B2.62.
- NO06** ELEVATOR MACHINE ROOM LIGHTING FIXTURES MOUNTED AT CEILING SURFACE.
- NO07** OUTSIDE PERIMETER LIGHTING FIXTURES ARE MOUNTED AT 7'-0" BELOW SOFFIT.
- NO08** CIRCUIT OUTSIDE PERIMETER LIGHTING FIXTURES VIA LIGHTING CONTACTOR ICP 5-61.