


**GENERAL NOTES:**  
 1. SEE DRAWINGS E9.21.52 AND E9.21.53 FOR LIGHTING PANEL SCHEDULES.  
 2. SEE DRAWINGS E9.30.01 AND E9.30.02 FOR FIXTURE SCHEDULES.

**KEYED NOTES:**  
 NO01 ALL NORMAL LIGHTING FIXTURES ON THIS DRAWING ARE CIRCLED FROM PANEL SL2A LOCATED IN ELECTRICAL ROOM 5-1-10.  
 NO02 ALL EMERGENCY LIGHTING FIXTURES AND EXIT SIGNS ON THIS DRAWING ARE CIRCLED FROM PANEL 5E5A LOCATED IN ELECTRICAL ROOM 3-2-66. LIGHTING IN STAIR NO. 2 TO BE CIRCLED FROM PANEL B1E5A IN ELECTRICAL ROOM B1-2-31.  
 NO03 ALL FIXTURES ARE MOUNTED 9'-5" A.F.F. UNLESS OTHERWISE NOTED.  
 NO04 CORRIDOR FIXTURES (W1) ARE MOUNTED 12'-7" A.F.F.  
 NO05 FOR LIGHTING CONTACTOR WIRING DIAGRAM, SEE E3.82.82.  
 NO06 ELEVATOR MACHINE ROOM LIGHTING FIXTURES MOUNTED AT CEILING SURFACE.  
 NO07 OUTSIDE PERIMETER LIGHTING FIXTURES ARE MOUNTED AT 7'-0" BELOW SOFFIT.  
 NO08 CIRCUIT OUTSIDE PERIMETER LIGHTING FIXTURES VIA LIGHTING CONTACTOR LCP 5-61. (CIRCUITS 7, 9)

**1 LEVEL 5 LIGHTING PLAN**  
 SCALE: 1/8" = 1'-0"

**2 LEVEL 6 ELEVATOR ROOM LIGHTING PLAN**  
 SCALE: 1/8" = 1'-0"



108031400-E8E-8600-A036

	Knight Jacobs Joint Venture 701 Scoborn Road, MS B253 Oak Ridge, TN 37830	<b>KNIGHT</b> Knight Advanced Technology
	865-241-8433 for 865-241-3400	

PROJECT NAME:  
**SPALLATION NEUTRON SOURCE  
 CENTRAL LAB AND OFFICE BUILDING  
 ELECTRICAL LIGHTING PLAN  
 LEVEL 05, SECTOR 61**

1	4B	49	50	PLANT	8	BLDG	8600	FL	1	SH.	1	OF	TYPE	CLASS
3	E	X	X											U
REV	51	NC	NA	53	WBS	1.8.3.14								E3.05.61

REV	DATE	DESCRIPTION	DSN	CHK	DEPT	DATE	PE	DATE	PJ	DATE	REQ	DATE	UTB	DATE	RPE	RPE NO	DATE
1		CERTIFIED FOR CONSTRUCTION - 12/20/01		TLW	KJS												
0		CERTIFIED FOR CONSTRUCTION - 5/15/01		TLW	KJS												

NO REPRESENTATION OR WARRANTY, EXPRESSED OR IMPLIED, IS MADE AS TO THE ACCURACY, COMPLETENESS OR USEFULNESS OF THE INFORMATION OR STATEMENTS CONTAINED IN THESE DRAWINGS, OR THAT THE USE OR DISCLOSURE OF ANY INFORMATION, APPARATUS, METHOD, OR PROCESS DISCLOSED IN THESE DRAWINGS MAY NOT INFRINGE PRIVATE RIGHTS OF OTHERS. NO LIABILITY IS ASSUMED WITH RESPECT TO THE USE OF, OR FOR DAMAGES RESULTING FROM THE USE OF ANY INFORMATION, APPARATUS, METHOD, OR PROCESS DISCLOSED IN THESE DRAWINGS. DRAWINGS MADE AVAILABLE FOR INFORMATION TO BIDDERS ARE NOT TO BE USED FOR OTHER PURPOSES AND ARE TO BE RETURNED UPON REQUEST OF THE FORMING CONTRACTOR.

THIS DOCUMENT CONTROLLED BY  
 CHANGE CONTROL SYSTEM  
 ENGINEERING PROCEDURE SNS-ENG-0001

SECTION AND DETAIL KEY

AutoCAD