SUPPLY: [ ] – BOTT. [X] – TOP [ ] – LUGS [X] –MAIN BKR.
TYPE: [ ] – 3P3W [X] – 3P4W [X] – WITH GRD. BAR
MAINS: 100 A 14000 A.I.C.
PANEL B1MESHOP1
[ ] – LTG. [ ] – RECEPT. [X] –POWER NEMA 1
MOUNTING [ ] –SURFACE [ ] – FLUSH [ ] –COLUMN
VOLTAGE: [ ] –120 / 208 [X] –277 / 480 [ ] 480 /
100 A. MAIN BKR. WITH: [ ] – SHUNT TRIP [ ] – ADJ. TRIP [ ] –G.F.P.

ME SHOP

CKT. NO.	TRIP	NO. OF POLES	USED FOR	COL. #1 VOLT – AMPS A	B	C	COL. #2 VOLT – AMPS A	B	C	USED FOR	NO. OF POLES	TRIP	CKT. NO.
1				5760						SPACE			2
3	50	3	TRANSFORMER-B1MESHOP1		5760					SPACE			4
5			30 kVA			5760				SPACE			6
7			SPACE							SPACE			8
9			SPACE							SPACE			10
11			SPACE							SPACE			12
13			SPACE							SPACE			14
15			SPACE							SPACE			16
17			SPACE							SPACE			18
19			SPACE							SPACE			20
21			SPACE							SPACE			22
23			SPACE							SPACE			24
25			SPACE							SPACE			26
27			SPACE							SPACE			28
29			SPACE							SPACE			30
31													32
33													34
35													36
37													38
39													40
41													42

PHASE TOTALS COL. #1	5760	5760	5760
PHASE TOTALS COL. #2	0	0	0
PHASE TOTAL VA	5760	5760	5760

TOTAL 3 PHASE CONNECTED 17 KVA 21 AMPS

file: panelsch_105_2a2b

SUPPLY: [ ] – BOTT. [ ] – TOP [ ] – LUGS [X] –MAIN BKR.
TYPE: [ ] – 3P3W [X] – 3P4W [X] – WITH GRD. BAR
MAINS: 100 A 10000 A.I.C.
PANEL B1MESHOP2
[ ] – LTG. [ ] – RECEPT. [X] –POWER NEMA 1
MOUNTING [X] –SURFACE [ ] – FLUSH [ ] –COLUMN
VOLTAGE: [X] –120 / 208 [ ] –277 / 480 [X] 480 /
100 A. MAIN BKR. WITH: [ ] – SHUNT TRIP [ ] – ADJ. TRIP [ ] –G.F.P.

ME SHOP

CKT. NO.	TRIP	NO. OF POLES	USED FOR	COL. #1 VOLT – AMPS A	B	C	COL. #2 VOLT – AMPS A	B	C	USED FOR	NO. OF POLES	TRIP	CKT. NO.
1			SPACE							SPACE			2
3			SPACE							SPACE			4
5			SPACE							SPACE			6
7			SPACE							SPACE			8
9			SPACE							SPACE			10
11			SPACE							SPACE			12
13			SPACE							SPACE			14
15			SPACE							SPACE			16
17			SPACE							SPACE			18
19			SPACE							SPACE			20
21			SPACE							SPACE			22
23			SPACE							SPACE			24
25			SPACE							SPACE			26
27			SPACE							SPACE			28
29			SPACE							SPACE			30
31													32
33													34
35													36
37													38
39													40
41													42

PHASE TOTALS COL. #1	0	0	0
PHASE TOTALS COL. #2	0	0	0
PHASE TOTAL VA	0	0	0

TOTAL 3 PHASE CONNECTED 0 KVA 0 AMPS

file: panelsch_106_2a2b

SUPPLY: [ ] – BOTT. [X] – TOP [X] – LUGS [ ] –MAIN BKR.
TYPE: [ ] – 3P3W [X] – 3P4W [X] – WITH GRD. BAR
MAINS: 100 A 14000 A.I.C.
PANEL B1ALIGSHOP1
[ ] – LTG. [ ] – RECEPT. [X] –POWER NEMA 1
MOUNTING [X] –SURFACE [ ] – FLUSH [ ] –COLUMN
VOLTAGE: [X] –120 / 208 [ ] –277 / 480 [ ] 480 /
100 A. MAIN BKR. WITH: [ ] – SHUNT TRIP [ ] – ADJ. TRIP [ ] –G.F.P.

ALIGNEMENT SHOP

CKT. NO.	TRIP	NO. OF POLES	USED FOR	COL. #1 VOLT – AMPS A	B	C	COL. #2 VOLT – AMPS A	B	C	USED FOR	NO. OF POLES	TRIP	CKT. NO.
1			SPACE							SPACE			2
3			SPACE							SPACE			4
5			SPACE							SPACE			6
7			SPACE							SPACE			8
9			SPACE							SPACE			10
11			SPACE							SPACE			12
13			SPACE							SPACE			14
15			SPACE							SPACE			16
17			SPACE							SPACE			18
19			SPACE							SPACE			20
21			SPACE							SPACE			22
23			SPACE							SPACE			24
25			SPACE							SPACE			26
27			SPACE							SPACE			28
29			SPACE							SPACE			30
31													32
33													34
35													36
37													38
39													40
41													42

PHASE TOTALS COL. #1	0	0	0
PHASE TOTALS COL. #2	0	0	0
PHASE TOTAL VA	0	0	0

TOTAL 3 PHASE CONNECTED 0 KVA 0 AMPS

file: panelsch_107_2a2b

SUPPLY: [ ] – BOTT. [X] – TOP [ ] – LUGS [X] –MAIN BKR.
TYPE: [ ] – 3P3W [X] – 3P4W [X] – WITH GRD. BAR
MAINS: 100 A 14000 A.I.C.
PANEL B1MAGSHOP1
[ ] – LTG. [ ] – RECEPT. [X] –POWER NEMA 1
MOUNTING [X] –SURFACE [ ] – FLUSH [ ] –COLUMN
VOLTAGE: [X] –120 / 208 [X] –277 / 480 [ ] 480 /
100 A. MAIN BKR. WITH: [ ] – SHUNT TRIP [ ] – ADJ. TRIP [ ] –G.F.P.

MAGNET SHOP

CKT. NO.	TRIP	NO. OF POLES	USED FOR	COL. #1 VOLT – AMPS A	B	C	COL. #2 VOLT – AMPS A	B	C	USED FOR	NO. OF POLES	TRIP	CKT. NO.
1			TRANSFORMER	5760						SPACE			2
3	50	3	B1MAGSHOPT2		5760					SPACE			4
5			30 kVA			5760				SPACE			6
7			SPACE							SPACE			8
9			SPACE							SPACE			10
11			SPACE							SPACE			12
13			SPACE							SPACE			14
15			SPACE							SPACE			16
17			SPACE							SPACE			18
19			SPACE							SPACE			20
21			SPACE							SPACE			22
23			SPACE							SPACE			24
25			SPACE							SPACE			26
27			SPACE							SPACE			28
29			SPACE							SPACE			30
31													32
33													34
35													36
37													38
39													40
41													42

PHASE TOTALS COL. #1	5760	5760	5760
PHASE TOTALS COL. #2	0	0	0
PHASE TOTAL VA	5760	5760	5760

TOTAL 3 PHASE CONNECTED 17 KVA 21 AMPS

file: panelsch_108_2a2b

SUPPLY: [ ] – BOTT. [X] – TOP [ ] – LUGS [X] –MAIN BKR.
TYPE: [ ] – 3P3W [X] – 3P4W [X] – WITH GRD. BAR
MAINS: 100 A 10000 A.I.C.
PANEL B1MAGSHOP2
[ ] – LTG. [ ] – RECEPT. [X] –POWER NEMA 1
MOUNTING [X] –SURFACE [ ] – FLUSH [ ] –COLUMN
VOLTAGE: [X] –120 / 208 [ ] –277 / 480 [X] 480 /
100 A. MAIN BKR. WITH: [ ] – SHUNT TRIP [ ] – ADJ. TRIP [ ] –G.F.P.

MAGNET SHOP

CKT. NO.	TRIP	NO. OF POLES	USED FOR	COL. #1 VOLT – AMPS A	B	C	COL. #2 VOLT – AMPS A	B	C	USED FOR	NO. OF POLES	TRIP	CKT. NO.
1			SPACE							SPACE			2
3			SPACE							SPACE			4
5			SPACE							SPACE			6
7			SPACE							SPACE			8
9			SPACE							SPACE			10
11			SPACE							SPACE			12
13			SPACE							SPACE			14
15			SPACE							SPACE			16
17			SPACE							SPACE			18
19			SPACE							SPACE			20
21			SPACE							SPACE			22
23			SPACE							SPACE			24
25			SPACE							SPACE			26
27			SPACE							SPACE			28
29			SPACE							SPACE			30
31													32
33													34
35													36
37													38
39													40
41													42

PHASE TOTALS COL. #1	0	0	0
PHASE TOTALS COL. #2	0	0	0
PHASE TOTAL VA	0	0	0

TOTAL 3 PHASE CONNECTED 0 KVA 0 AMPS

file: panelsch_109_2a2b

SUPPLY: [ ] – BOTT. [X] – TOP [X] – LUGS [X] –MAIN BKR.
TYPE: [ ] – 3P3W [X] – 3P4W [X] – WITH GRD. BAR
MAINS: 225 A 25,000 A.I.C.
PANEL B1RFSHOPT1
[ ] – LTG. [ ] – RECEPT. [X] –POWER NEMA 1
MOUNTING [X] –SURFACE [ ] – FLUSH [X] –277 / 480 [X] 480 /
225 A. MAIN BKR. WITH: [ ] – SHUNT TRIP [ ] – ADJ. TRIP [ ] –G.F.P.

RING RF CAVITY TEST SHOP

CKT. NO.	TRIP	NO. OF POLES	USED FOR	COL. #1 VOLT – AMPS A	B	C	COL. #2 VOLT – AMPS A	B	C	USED FOR	NO. OF POLES	TRIP	CKT. NO.
1			TRANSFORMER	25000						SPACE			2
3	100	3	B1RFSHOPT1		25000					SPACE			4
5			75KVA			25000				SPACE			6
7			SPACE							SPACE			8
9			SPACE							SPACE			10
11			SPACE							SPACE			12
13			SPACE							SPACE			14
15			SPACE							SPACE			16
17			SPACE							SPACE			18
19			SPACE							SPACE			20
21			SPACE							SPACE			22
23			SPACE							SPACE			24
25			SPACE							SPACE			26
27			SPACE							SPACE			28
29			SPACE							SPACE			30
31			SPACE							SPACE			32
33			SPACE							SPACE			34
35			SPACE							SPACE			36
37			SPACE							SPACE			38
39			SPACE							SPACE			40
41			SPACE							SPACE			42

PHASE TOTALS COL. #1	25000	25000	25000
PHASE TOTALS COL. #2	0	0	0
PHASE TOTAL VA	25000	25000	25000

TOTAL 3 PHASE CONNECTED 75 KVA 90 AMPS

file: panelsch_110_2a2b

SUPPLY: [ ] – BOTT. [X] – TOP [ ] – LUGS [X] –MAIN BKR.
TYPE: [ ] – 3P3W [X] – 3P4W [X] – WITH GRD. BAR
MAINS: 225 A 10000 A.I.C.
PANEL B1RFSHOP2
[ ] – LTG. [ ] – RECEPT. [X] –POWER NEMA 1
MOUNTING [X] –SURFACE [ ] – FLUSH [ ] –COLUMN
VOLTAGE: [X] –120 / 208 [ ] –277 / 480 [X] 480 /
225 A. MAIN BKR. WITH: [ ] – SHUNT TRIP [ ] – ADJ. TRIP [ ] –G.F.P.

VACCUM SHOP

CKT. NO.	TRIP	NO. OF POLES	USED FOR	COL. #1 VOLT – AMPS A	B	C	COL. #2 VOLT – AMPS A	B	C	USED FOR	NO. OF POLES	TRIP	CKT. NO.
1			SPACE							SPACE			2
3			SPACE							SPACE			4
5			SPACE							SPACE			6
7			SPACE							SPACE			8
9			SPACE							SPACE			10
11			SPACE							SPACE			12
13			SPACE							SPACE			14
15			SPACE							SPACE			16
17			SPACE							SPACE			18
19			SPACE							SPACE			20
21			SPACE							SPACE			22
23			SPACE							SPACE			24
25			SPACE							SPACE			26
27			SPACE							SPACE			28
29			SPACE							SPACE			30
31			SPACE							SPACE			32
33			SPACE							SPACE			34
35			SPACE							SPACE			36
37			SPACE							SPACE			38
39			SPACE							SPACE			40
41			SPACE							SPACE			42

PHASE TOTALS COL. #1	0	0	0
PHASE TOTALS COL. #2	0	0	0
PHASE TOTAL VA	0	0	0

TOTAL 3 PHASE CONNECTED 0 KVA 0 AMPS

file: panelsch_111_2a2b

SUPPLY: [ ] – BOTT. [ ] – TOP [ ] – LUGS [X] –MAIN BKR.
TYPE: [ ] – 3P3W [X] – 3P4W [X] – WITH GRD. BAR
MAINS: 600 A 30000 A.I.C.
PANEL B1PSUPPLY1
[ ] – LTG. [ ] – RECEPT. [X] –POWER NEMA 1
MOUNTING [X] –SURFACE [ ] – FLUSH [ ] –COLUMN
VOLTAGE: [ ] –120 / 208 [X] –277 / 480 [X] 480 /
400 A. MAIN BKR. WITH: [ ] – SHUNT TRIP [ ] – ADJ. TRIP [ ] –G.F.P.

RING RF CAVITY TEST SHOP

CKT. NO.	TRIP	NO. OF POLES	USED FOR	COL. #1 VOLT – AMPS A	B	C	COL. #2 VOLT – AMPS A	B	C	USED FOR	NO. OF POLES	TRIP	CKT. NO.
1			TRANSFORMER	25000									2
3	100	3	B1PSUPPLYT1		25000								4
5			75KVA			25000							6
7													8
9													10
11													12
13													14
15													16
17													18
19													20
21													22
23													24
25													26
27													28
29													30
31													32
33													34
35													36
37													38
39													40
41													42

PHASE TOTALS COL. #1	25000	25000	25000
PHASE TOTALS COL. #2	0	0	0
PHASE TOTAL VA	25000	25000	25000

TOTAL 3 PHASE CONNECTED 75 KVA 90 AMPS

file: panelsch_132_2a2b

SUPPLY: [ ] – BOTT. [X] – TOP [ ] – LUGS [X] –MAIN BKR.
TYPE: [ ] – 3P3W [X] – 3P4W [X] – WITH GRD. BAR
MAINS: 225 A 10000 A.I.C.
PANEL B1PSUPPLY2
[ ] – LTG. [ ] – RECEPT. [X] –POWER NEMA 1
MOUNTING [X] –SURFACE [ ] – FLUSH [ ] –COLUMN
VOLTAGE: [X] –120 / 208 [ ] –277 / 480 [X] 480 /
225 A. MAIN BKR. WITH: [ ] – SHUNT TRIP [ ] – ADJ. TRIP [ ] –G.F.P.

VACCUM SHOP W /FEED THROUGH LUGS

CKT. NO.	TRIP	NO. OF POLES	USED FOR	COL. #1 VOLT – AMPS A	B	C	COL. #2 VOLT – AMPS A	B	C	USED FOR	NO. OF POLES	TRIP	CKT. NO.
1										SPACE			2
3	50	3	PANEL B1ALIGSHOP1							SPACE			4
5										SPACE			6
7			SPACE							SPACE			8
9			SPACE							SPACE			10
11			SPACE							SPACE			12
13			SPACE							SPACE			14
15			SPACE							SPACE			16
17			SPACE							SPACE			18
19			SPACE							SPACE			20
21			SPACE							SPACE			22
23			SPACE							SPACE			24
25			SPACE							SPACE			26
27			SPACE							SPACE			28
29			SPACE							SPACE			30
31			SPACE							SPACE			32
33			SPACE							SPACE			34
35			SPACE							SPACE			36
37			SPACE							SPACE			38
39			SPACE							SPACE			40
41			SPACE							SPACE			42

PHASE TOTALS COL. #1	0	0	0
PHASE TOTALS COL. #2	0	0	0
PHASE TOTAL VA	0	0	0

TOTAL 3 PHASE CONNECTED 0 KVA 0 AMPS

file: panelsch_133_2a2b

NO REPRESENTATION OR WARRANTY, EXPRESSED OR IMPLIED, IS MADE AS TO THE ACCURACY, COMPLETENESS OR USEFULNESS OF THE INFORMATION OR STATEMENTS CONTAINED IN THESE DRAWINGS, OR THAT THE USE OR DISCLOSURE OF ANY INFORMATION, APPARATUS, METHOD, OR PROCESS DISCLOSED IN THESE DRAWINGS MAY NOT INFRINGE PRIVATE RIGHTS OF OTHERS. NO LIABILITY IS ASSUMED WITH RESPECT TO THE USE OF, OR FOR DAMAGES RESULTING FROM THE USE OF ANY INFORMATION, APPARATUS, METHOD, OR PROCESS DISCLOSED IN THESE DRAWINGS. DRAWINGS MADE AVAILABLE FOR INFORMATION TO BIDDER ARE NOT TO BE USED FOR OTHER PURPOSES AND ARE TO BE RETURNED UPON REQUEST OF THE FORWARDING CONTRACTOR.

NUMBER OF SECTION OR DETAIL
DRAWING ON WHICH SECTION OR DETAIL IS SHOWN OR TAKEN
SECTION AND DETAIL KEY

THIS DOCUMENT CONTROLLED BY
CHANGE CONTROL SYSTEM 4
ENGINEERING PROCEDURE SNS-ENG-0001

REV	CHANGE TYPE	CHANGE CONTROL SYSTEM	DRAWING NUMBER	DESCRIPTION	DSN	CHK	DEPT	DATE	PE	DATE	PJ	DATE	REQ	DATE	UTB	DATE	RPE	RPE NO	DATE	ST	CV	EC	EE	EM	IE	M	PD	SE	AR
0				CERTIFIED FOR CONSTRUCTION – 05/15/2001	RO	RL											VGS	106009	5/15/01	SC	AW	BS	RL	BS	BJ	--	BS	--	WS
REV				DESCRIPTION	DSN	CHK	DEPT	DATE	PE	DATE	PJ	DATE	REQ	DATE	UTB	DATE	RPE	RPE NO	DATE	ST	CV	EC	EE	EM	IE	M	PD	SE	AR
REVISION OR ISSUE PURPOSE								REVISION APPROVALS												SQUAD CHECK									

RPE
TREVOR G. STEPHAN
REGISTERED ENGINEER
No. 0010000
STATE OF TENNESSEE
5-10-01

DSN	R.OLAPOUR	5/15/01
DRW	S.BARNETT	5/15/01
CHK	R.LENNIG	5/15/01
DEPT		
PE		10/1/01
PJ		10/1/01
REQ		
UTB		10/9/01

0 REV. 5-10-01 DATE
DRAWING APPROVALS

108031400-E8E-8600-A158

Knight/Jacobs Joint Venture
701 Scarboro Road, MS 8253
Oak Ridge, TN 37830
865-241-9433
fax 865-241-3400

KNIGHT
Knight Advanced Technology
4710 East Elwood, Suite 29
Phoenix, AZ 85040

UT-BATTELLE
Oak Ridge National Laboratory
managed for the DEPARTMENT OF ENERGY under U.S. GOVERNMENT contract DE-AC05-00OR22725
UT-BATTELLE, LLC. ■ Oak Ridge, Tennessee

PROJECT NAME:
SPALLATION NEUTRON SOURCE
CENTRAL LAB AND OFFICE BUILDING
PANEL SCHEDULES

1	48	49	50	PLANT	BLDG	FL	SH.	OF	TYPE	CLASS
3	E	X	X	8	8600		1	1	S	U
51		52		53	WBS		E9.21.51		REV	
NC		NA			1.8.3.14				0	

date: 05/08/2001 time: 14:05:50
device(s): DWG004
I:\ESS\PROJECTS\1000\1900_0400\1906_2874\45_PLOT\19-21-51.DWG