

SECTION 10200 LOUVERS

PART 1 - GENERAL

1.1 SUMMARY

- A. This Section includes the following:
 - 1. Fixed, extruded-aluminum wall louvers.
 - 2. Screens
 - 3. Blank-off panels for louvers.
- B. Related Sections:
 - 1. Division 8 Section "Exterior Wall Systems - General", for requirements for exterior wall components.

1.2 DEFINITIONS

- A. Louver Terminology: Definitions of terms for metal louvers contained in AMCA 501 apply to this Section, unless otherwise defined in this Section or in referenced standards.

1.3 PERFORMANCE REQUIREMENTS

- A. Structural Performance: Provide exterior metal louvers capable of withstanding the effects of loads and stresses from wind and normal thermal movement without evidencing permanent deformation of louver components including blades, frames, and supports; noise or metal fatigue caused by louver blade rattle or flutter; or permanent damage to fasteners and anchors.
 - 1. Wind Load: Uniform pressure (velocity pressure) of 40 lbf/sq. ft., acting inward or outward.
 - 2. Thermal Movements: Provide louvers that allow for thermal movements resulting from the following maximum change (range) in ambient and surface temperatures by preventing buckling, opening of joints, overstressing of components, and other detrimental effects:
 - a. Temperature Change (Range): 120 deg F, ambient; 180 deg F, material surfaces.

1.4 SUBMITTALS

- A. Product Data: For each type of product specified.
- B. Shop Drawings: For louver units and accessories. Include plans; elevations; sections; and details showing profiles, angles, and spacing of louver blades. Show unit dimensions related to wall openings and construction; free area for each size indicated; profiles of frames at jambs, heads, and sills; and anchorage details and locations.
 - 1. For installed louvers and vents indicated to comply with design loadings, include structural analysis data signed and sealed by the qualified professional engineer responsible for their preparation.
- C. Samples for Initial Selection: Manufacturer's color charts showing the full range of colors available for units with factory-applied color finishes.

1.5 QUALITY ASSURANCE

- A. Source Limitations: Obtain louvers and vents through one source from a single manufacturer where alike in one or more respects regarding type, design, or factory-applied color finish.
- B. Welding Standards: As follows:
 - 1. Comply with AWS D1.2, "Structural Welding Code--Aluminum."

1.6 PROJECT CONDITIONS

- A. Field Measurements: Verify louver openings by field measurements before fabrication and indicate measurements on Shop Drawings. Coordinate fabrication schedule with construction progress to avoid delaying the Work.
 - 1. Established Dimensions: Where field measurements cannot be made without delaying the Work, establish opening dimensions and proceed with fabricating louvers without field measurements. Coordinate construction to ensure that actual opening dimensions correspond to established dimensions.

PART 2 - PRODUCTS

2.1 MANUFACTURERS

- A. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
 - 1. Aiolite Co.
 - 2. Construction Specialties, Inc.
 - 3. Dowco Products Group.
 - 4. Ruskin Manufacturing.

2.2 MATERIALS

- A. Aluminum Extrusions: ASTM B 221, alloy 6063-T5 or T-52.
- B. Aluminum Sheet: ASTM B 209, alloy 3003 or 5005 with temper as required for forming, or as otherwise recommended by metal producer for required finish.
- C. Fasteners: Of same basic metal and alloy as fastened metal or 300 series stainless steel, unless otherwise indicated. Do not use metals that are incompatible with joined materials.
- D. Use Phillips flat-head screws for exposed fasteners.
- E. Anchors and Inserts: Of type, size, and material required for loading and installation indicated. Use nonferrous metal or hot-dip galvanized anchors and inserts for exterior installations and elsewhere as needed for corrosion resistance. Use toothed steel or expansion bolt devices for drilled-in-place anchors.
- F. Bituminous Paint: Cold-applied asphalt mastic complying with SSPC-Paint 12 but containing no asbestos fibers, or cold-applied asphalt emulsion complying with ASTM D 1187.

2.3 FABRICATION, GENERAL

- A. Assemble louvers in factory to minimize field splicing and assembly. Disassemble units as necessary for shipping and handling limitations. Clearly mark units for reassembly and coordinated installation.

- B. Maintain equal louver blade spacing to produce uniform appearance.
- C. Fabricate frames, including integral sills, to fit in openings of sizes indicated, with allowances made for fabrication and installation tolerances, adjoining materials' tolerances, and perimeter sealant joints.
 - 1. Frame Type: Channel type.
- D. Include supports, anchorages, and accessories required for complete assembly.
- E. Provide vertical mullions of type and at spacings indicated, but not more than recommended by manufacturer, or 72 inches o.c., whichever is less. At horizontal joints between louver units, provide horizontal mullions, unless continuous vertical assemblies are indicated.
- F. Provide sill extensions and loose sills made of same material as louvers where indicated or required for drainage to exterior and to prevent water penetrating to interior.
- G. Join frame members to one another and to fixed louver blades with fillet welds, threaded fasteners, or both, as standard with louver manufacturer, concealed from view; unless otherwise indicated or size of louver assembly makes bolted connections between frame members necessary.

2.4 FIXED, EXTRUDED-ALUMINUM WALL LOUVERS

- A. Louver Construction: Provide fixed-blade louvers with extruded-aluminum frames and blades.
- B. Drainable Blade Horizontal Louvers: Drainable-blade type complying with the following:
 - 1. Louver Depth: Depth indicated on Drawings.
 - 2. Frame Thickness: 0.081 inch.
 - 3. Blade Thickness: 0.081 inch.
 - 4. Blade Angle: 30 degrees.
 - 5. Free Area: Not less than 8 sq. ft. for 48-inch- wide by 48-inch- high louver.
 - 6. Air Performance: Not more than 0.09-inch wg static pressure drop at 740-fpm free-area velocity.
 - 7. AMCA Seal: Mark units with AMCA Certified Ratings Seal.

2.5 LOUVER SCREENS

- A. Provide each exterior louver with louver screens complying with the following requirements:
 - 1. Screen Location for Fixed Louvers: Interior face.
 - 2. Screening Type: Bird screening.
- B. Secure screens to louver frames with stainless-steel machine screws, spaced a maximum of 6 inches from each corner and at 12 inches o.c.
- C. Louver Screen Frames: Fabricate screen frames with mitered corners to louver sizes indicated and to comply with the following requirements:
 - 1. Metal: Same kind and form of metal as indicated for louver to which screens are attached.
 - a. Reinforce extruded-aluminum screen frames at corners with clips.
 - 2. Finish: Same finish as louver frames to which louver screens are attached.
 - 3. Type: Non-rewirable, U-shaped frames for permanently securing screen mesh.
- D. Louver Screening for Aluminum Louvers:
 - 1. Bird Screening: Aluminum, 1/2-inch- square mesh, 0.063-inch wire.

2.6 BLANK-OFF PANELS

- A. General: Fabricate blank-off panels from materials and to sizes indicated and comply with the following requirements:
 - 1. Finish: Same as finish applied to louvers.
 - 2. Attach blank-off panels to back of louver frames with stainless-steel sheet-metal screws.
- B. Uninsulated, Blank-off Panels: Metal sheet complying with the following requirements:
 - 1. Aluminum sheet for aluminum louvers, thickness: 0.050 inch.
- C. Insulated, Blank-off Panels: Laminated metal-faced panels consisting of insulating core surfaced on back and front with metal sheets, complying with the following requirements:
 - 1. Thickness: 1 inch.
 - 2. Metal Facing Sheets: Aluminum sheet, 0.032 inch thick.
 - 3. Insulating Core: Extruded-polystyrene insulation board complying with ASTM C 578, Type VII.
 - 4. Edge Treatment: Trim perimeter edges of blank-off panels with louver manufacturer's standard extruded-aluminum-channel frames 0.081 inch thick, with corners mitered and with same finish as panels.
 - 5. Seal perimeter joints between panel faces and louver frames with 1/8-by-1-inch PVC compression gaskets.

2.7 ALUMINUM FINISHES

- A. Finish designations prefixed by AA comply with system established by the Aluminum Association for designating aluminum finishes.
- B. High-Performance Organic Coating Finish: AA-C12C42R1x (Chemical Finish: cleaned with inhibited chemicals; Chemical Finish: acid-chromate-fluoride-phosphate conversion coating; Organic Coating: as specified below). Prepare, pretreat, and apply coating to exposed metal surfaces to comply with coating and resin manufacturers' written instructions.
 - 1. Fluoropolymer Two-Coat Coating System: Manufacturer's standard two-coat, thermocured system consisting of specially formulated inhibitive primer and fluoropolymer color topcoat containing not less than 70 percent polyvinylidene fluoride resin by weight; complying with AAMA 2605.
 - a. Color and Gloss: Match Construction Manager's sample.
 - b. Pearlescent Finish: Provide pearlescent finish containing mica flakes.

PART 3 - EXECUTION

3.1 PREPARATION

- A. Coordinate Setting Drawings, diagrams, templates, instructions, and directions for installation of anchorages that are to be embedded in concrete or masonry construction. Coordinate delivery of such items to Project site.

3.2 INSTALLATION

- A. Locate and place louver units level, plumb, and at indicated alignment with adjacent work.
- B. Use concealed anchorages where possible. Provide brass or lead washers fitted to screws where required to protect metal surfaces and to make a weathertight connection.
- C. Form closely fitted joints with exposed connections accurately located and secured.

- D. Provide perimeter reveals and openings of uniform width for sealants and joint fillers, as indicated.
- E. Repair finishes damaged by cutting, welding, soldering, and grinding. Restore finishes so no evidence remains of corrective work. Return items that cannot be refinished in the field to the factory, make required alterations, and refinish entire unit or provide new units.
- F. Protect galvanized and nonferrous-metal surfaces from corrosion or galvanic action by applying a heavy coating of bituminous paint on surfaces that will be in contact with concrete, masonry, or dissimilar metals.
- G. Install concealed gaskets, flashings, joint fillers, and insulation, as louver installation progresses, where weathertight louver joints are required. Comply with Division 7 Section "Joint Sealants" for sealants applied during louver installation.

3.3 ADJUSTING, CLEANING, AND PROTECTING

- A. Periodically clean exposed surfaces of louvers and vents that are not protected by temporary covering to remove fingerprints and soil during construction period. Do not let soil accumulate until final cleaning.
- B. Before final inspection, clean exposed surfaces with water and a mild soap or detergent not harmful to finishes. Thoroughly rinse surfaces and dry.
- C. Protect louvers and vents from damage during construction. Use temporary protective coverings where needed and approved by louver manufacturer. Remove protective covering at the time of Substantial Completion.
- D. Restore louvers and vents damaged during installation and construction so no evidence remains of corrective work. If results of restoration are unsuccessful, as determined by Construction Manager, remove damaged units and replace with new units.
 - 1. Clean and touch up minor abrasions in finishes with air-dried coating that matches color and gloss of, and is compatible with, factory-applied finish coating.

END OF SECTION 10200