


DETAIL "H"
POWER WIRING DIAGRAM

LEGEND:

--- RACK FABRICATOR WIRING.



DETAIL "I"
POWER WIRING DIAGRAM

NOTES:

- 1 PANEL FABRICATOR SHALL PROVIDE ALL MISC. HARDWARE REQUIRED TO ASSEMBLE INCLUDING DIN RAILS, PANDUIT, END CLAMPS, TERMINAL IDENTIFICATION NUMBERS, UNISTRUT AND ASSOCIATED SPRING NUTS, ETC...
- 2 ITEMS TO BE PROCURED AND SUPPLIED BY PANEL FABRICATOR.
- 3 POWER WIRING TO BE #12 AWG TYPE "TC" CABLE. GROUND WIRES TO BE #12AWG 75° COPPER.

2.18.02

DES	BILL DEVAN	2.18.02	Oak Ridge National Laboratory <small>ORNL is managed by ORNL for the U.S. Department of Energy under contract number DE-AC05-84OR21400</small>		
DWN	JUNE SAFIEH	2.18.02			
CHK					
L3TL			Spallation Neutron Source ICS RACK FABRICATION DETAILS H & I		
LE					
STL			DRAWING NUMBER	REV	
REVISION OR ISSUE PURPOSE		REVISION APPROVALS	DRAWING APPROVALS	DATE	109020000-R8D-8000-F007